



# MOUNT CARMEL GLOBAL SCHOOL

(A unit of Mount Carmel Educational Society)

Affiliated to the Central Board of Secondary Education (Affl. No. 3630079)

Survey No. 138, Badangpet, Hyderabad- 500 058, Telangana, India.

E-mail : info@mountcarmelhyd.com, Phone : 94903 72354, 94415 15253

Date: 25 June, 2023

From,

Mount Carmel Global School  
Survey #138, Badangpet  
Hyderabad-500058

To,

District Fire Officer,  
Malkajiri, Pin-500076

Sub: Submission of Annexure-I for Self Certification of Fire Safety Measures (G.O.No. 56) by School Management, Mount Carmel Global School, Badangpet, Hyd 58

Sir,

With reference to the subject cited above, we are submitting Annexure I (as per CO. 56) for Self Certification of Fire Safety Measures by School Management for our School ETR from 2023-24 to 2031) Please consider the matter at the earliest for which we would be grateful to you

Thanking you.

Yours Sincerely

(Mount Carmel Global School)

Correspondent/Principal

  
**Mrs. Suprabha Hani**  
Principal  
Mount Carmel Global School  
Badangpet-58, R.R. Dist. T.S.

34  
21-6-2023

Received copy  
as per G.O. No. 56

21/6/2023  
District Fire Officer  
Malkajiri Division

# MOUNT CARMEL GLOBAL SCHOOL

(A unit of Mount Carmel Educational Society)

CBSE Affiliation No. 130247

Survey # 138, Badangpet Nagara Panchayat, Hyderabad-500 058.  
Visit : [www.mountcarmelhyd.com](http://www.mountcarmelhyd.com); E-mail : [info@mountcarmelhyd.com](mailto:info@mountcarmelhyd.com)  
Ph : 91-40-3252 3253 / 99593 11233

Date: 21<sup>st</sup> October, 2019

From:

Mount Carmel Global School  
Survey#138, Badangpet,  
Hyderabad -500058

To

District Fire Officer,  
Madhapur,  
RangaReddy, Pin-500081.

**Sub:** Submission of Annexure -I for Self Certification of Fire Safety Measures by School Management, Mount Carmel Global School, Badangpet, Hyd-58.


Sir,

With reference to the subject cited above, we are submitting Annexure I (as per G.O. 56) for Self Certification of Fire Safety Measures by School Management for our School ETR from 2018-19 to 2027.

Please consider the matter at the earliest for which we would be grateful to you.

Thanking you,

Yours Sincerely

  
(Mount Carmel Global School)  
Correspondent



*Attended*  
*EX*  
Mandal Educational Officer,  
M.P.P. Saroornagar, R.R. Dist

Mount Carmel Global School

  
Correspondent

**ANNEXURE - I**

(Annexure to G.O.Ms.No.56, Home (Ser.IV) Department, Dated:26.07.2019)

**Instructions to be followed for schools existing before 13.04.2009;**

**SELF CERTIFICATION FORM**

**Self Certification of Fire Safety Measures by School Management :**

**i) General Information for School Buildings of all categories i.e., A, B, C & D.**

Sl. No.	Details	
1	Date of the opening of the school building	11-02-2009
2	Name of the applicant	D.Vamsi KRISHNA
3	Name and address of the School	Mount Carmel Global School. Badangpet, Hyd - 784151 52-53
4	Telephone Number and email of the applicant	
5	Height of the building (in meters)	11.6 meters
6	No of floors	G+3 meters
7	Abutting Road width (in meters)	15 meters
8	Built-up area of each floor in Sq.Mtrs Stilt ----- Ground ----- Floor1 ----- Floor2 -----	Ground - 1272.40 mtrs 1st floor - 1365.93 mtrs 2nd floor - 1365.93 mtrs 3rd floor - 1365.93 mtrs
9	Number of Staircases Staircase 1---1.50 mtrs (width in meters) Staircase 2---1.50 mtrs (width in meters)	1.50 mtrs x 4 No. = 6.00 mtrs
10	Width of each Staircase	1.5 mtrs x 4 No.
11	Open Spaces Front ----- 6 mtrs (width in meters) i Side 1----- 6.00 mtrs (width in meters) g Side 2----- 2.00 mtrs (width in meters) n Rear----- 2.00 mtrs (width in meters) a	6 mtrs 6 mtrs 2 mtrs 2 mtrs

Signature with date of \_\_\_\_\_  
 School authority and Seal  
**Mrs. Suprabha Hani**  
 Principal  
 Mount Carmel Global School  
 Badangpet-58, R.R. Dist. T.S.

B) School Buildings with Ground plus two floors and less than 15 Meters in height.

Sl. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided
				Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.	36	42
2	First Aid Hose Reel (IS 884:1985)	1 No for every 1000 square meter	2x4	8
3	Terrace Tank over respective tower terrace	10000 Liters (5000 Liters additionally shall be provided if basement exceeds 200 square meters)	10,000	25,000
4	Automatic Sprinkler System (IS 15105:2002) The IS standard may be downloaded from <a href="http://www.bis.gov.in/">www.https://bis.gov.in/</a>	To be installed in basement. If area of basement exceeds 200 square meters	NO	NO
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup>	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)	450	900
<b>Additional Fire Safety Measures in lieu of deficiency in Setbacks.</b>				
1	Water Shower curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.		yes
2	Fire Brigade Inlet	02 Nos		yes

Note: If the floor area in a single floor more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal steel structure.

Signature with date of School authority and Seal

**Mrs. Suprabha Hani**  
Principal

Mount Carmel Global School  
Badangpet-58, R.R. Dist. T.S.


ii) General Fire Safety Measures which should be followed by all schools:-

Sl. No	General Fire Safety Measures	Whether followed Yes / No
1	The school building shall not be housed in temporary structures with roofs of tent cloth, thatched or any other combustible materials.	yes
2	It should be ensured that the available Fire Safety Equipment is always in good working condition.	yes
3	Pre-School, Kinder Garden and Class/Grade 1 Students shall be located on Ground Floor/level of Exit discharge and Class/Grade 2 Students shall be located not above One Floor higher than Ground Floor/level of Exit discharge	yes
4	Kitchen should be constructed/provided away from the school building	yes
5	All Schools shall prepare an Evacuation Plan in consultation with local Fire Officer	yes
6	All Teachers/Employees should be trained in operating the available Fire Safety Equipment in the building.	yes
7	All Exits/Escapes routes shall be kept free from any obstructions for free passage in case of any emergency.	yes
8	All the internal staircases, lifts, lobbies and corridors should be adequately ventilated and illuminated.	yes
9	If the school is provided with central Air-conditioning system, all safety measures as per Clause 10.1 of IS 14435:1997 should be followed.	yes
10	School Buildings shall be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safely.	yes
11	Any Hazardous/Combustible Material/Volatile Flammable Liquids shall not be stored in School Buildings	yes
12	DOs and DON'Ts in case of any Fire/Emergency shall be properly displayed at Strategic locations of the building.	yes
13	Auto Glow Sign Boards shall be provided indicating Exits/Escapes Routes.	yes
14	Electric Wiring in the entire building shall be checked and certified by the competent authority	yes

Contd/-6

5	Structural Stability of the building shall be checked and certified by the competent authority.	yes
16	Public Address System shall be provided for use in case of any emergency and this system shall cover the entire building.	yes
17	Detailed information regarding the number of students in each Class Room and the number of teachers/employees working shall be displayed at Strategic locations of the building.	yes
18	Display all Emergency supporting numbers such as nearest Fire Stations, Police Stations, Hospitals/ Ambulance etc. on all floors and at Strategic locations.	yes
19	A pictorial map with the details of Entries/Exits, details of Class Rooms/Laboratories/Staff Rooms and Open Place (Assembly Point) of the School Building shall be prepared and displayed in Strategic Locations.	yes
20	If Basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler system as per IS 15105:2002	yes

We.....School Management/Correspondent hereby certify that the information furnished is correct and if it is noticed at any time that the information provided is false, we understand that our school affiliation may be cancelled by the Concerned Authority. We have installed fire safety measures as per the Annexure I and undertake to maintain the same in good working condition at all times.

  
Signature with date of School authority and Seal

**Mrs. Suprabha Hant**  
Principal

**Mount Carmel Global School**  
Badangpet-58, R.R. Dist. T.S.

**RAJIV TRIVEDI**

**PRINCIPAL SECRETARY TO GOVERNMENT**

Copy to :  
The Divisional Fire Officer of concerned District.

GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE AND FIRE SERVICE DEPARTMENT

Office of the  
District Fire Officer,  
Malkajgiri.

We have received the self-declaration form as per GO no.56 according to GOVERNMENT OF TELANGANA STATE DISASTER RESPONSE AND FIRE SERVICE DEPARTMENT norms from **Mount Carmel Global School**, Survey # 138, Badangpet, Balapur Mandal Hyderabad-500058

GOVERNMENT OF TELANGANA  
ABSTRACT

Home Department - Fire Services - Directions of Hon'ble Supreme Court of India dated:13.04.2009 in W.P. No.483 of 2004 - Fire Safety measures to be followed in the Schools - Orders - Issued.

HOME (SERVICES.IV) DEPARTMENT

G.O.Ms.No.56.

Dated: 26.07.2019.  
Read the Following:-

1. Telangana Fire Service Act, 1999.
2. National Building Code of India, 2016.
3. Hon'ble Supreme Court of India Judgment dated:13.04.2009 in W.P. No.483 of 2004.
4. From the Director General of State Disaster Response and Fire Services, Telangana, Hyderabad Letter Rc.No. 8109/MSB/2016, dated:28.02.2018.
5. G.O.Rt.No.442 Home (Services.IV) Department, dated:28.03.2018.
6. From the Director General of State Disaster Response and Fire Services, Telangana, Hyderabad Letter Rc.No. 8109/MSB/2016, dated:29.05.2018.
7. From School Education (General) Department U.O.Note No.4590/SE.Genl/A2/2018-3, dated:14.08.2018.
8. From the Director General of State Disaster Response and Fire Services, Telangana, Hyderabad Lr.Rc.No.8109/MSB/2019, dated.22.06.2019.

(\*\*\*\*\*)

**ORDER:**

Hon'ble Supreme Court of India in its Judgment dated:13.04.2009 in W.P. No.483 of 2004 have issued the following directions keeping in view of the Safety and Security of School going children which has utmost importance:

"It has become imperative to direct that, Safety Measures as prescribed by the National Building Code of India, 2005 be implemented by all Government and Private Schools functioning in our Country.

- (i) Before Granting recognition or affiliation, the concerned State Government and Union Territories are directed to ensure that the buildings are safe and secure from every angle and they are constructed according to the safety norms incorporated in the National Building Code of India.
  - (ii) All Existing Government and Private Schools shall install fire extinguishing equipment within a period of Six Months.
  - (iii) The School Buildings be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safely.
  - (iv) Evaluation of structure aspect of the school may be carried out periodically. We direct that the concerned engineers and officials must strictly follow the National Building Code. The Safety Certificate be Issued only after proper Inspection. Dereliction In duty must attract Immediate disciplinary action against the concerned officials.
  - (v) Necessary training be Imparted to the staff and other officials of the school to use the Fire extinguishing equipment".
2. The Director General of State Disaster Response & Fire Services, Telangana, Hyderabad In his letter 4<sup>th</sup> read above has requested the Government to constitute an Expert Committee on Setbacks and Retrofitting of Fire Safety installations in the

Contd/-2



existing school buildings as per the directions of the Hon'ble Supreme Court. Accordingly, Government have constituted the Expert Committee with the following Members to suggest norms for different Educational institutions existing prior to the order of the Hon'ble Supreme Court Judgment and also to suggest standard norms applicable for such institutions regarding setbacks and retrofitting of the Fire Safety Installations in the existing School buildings vide G.O. 5<sup>th</sup> read above:

i	Director General, Telangana State Disaster Response & Fire Services Hyderabad	Chairman
ii	One expert from Telangana State Disaster Response & Fire Services Hyderabad	Member
iii	One expert from the Town & Country Planning Department, MASUD Department	Member
iv	Senior representative from Education Department	Member
v	Representative of School Management Association	Member

4. The Expert Committee has submitted its report with specific recommendations the Director General, TSDR & FS has submitted the recommendations to the Government vide letter 6<sup>th</sup> read above.

5. Subsequently, the Chief Secretary to Government has convened a meeting with all the concerned on 12.05.2019 on the fire safety issues in schools and decided to issue guidelines on the issues of Fire Safety in the Schools. The Director General, Telangana State Disaster Response & Fire Services Department has also furnished his remarks to Government vide letter 8<sup>th</sup> read above.

6. Government after careful consideration of the decisions taken in the meeting convened by the Chief Secretary to Government on 12.06.2019 and also further remarks of the Director General, Telangana State Disaster Response & Fire Services Department and in compliance of the directions of the Hon'ble Supreme Court of India in its Judgement dated:13.04.2009 in W.P. No.483 of 2004, here by order that, all Schools existing before the Hon'ble Supreme Court Order i.e., dated:13.04.2009, shall follow the Fire Safety norms as recommended by the Expert Committee as detailed in the **Annexure-I** appended to this order, for the purpose of obtaining the affiliation/recognition. Further Self Certification forms shall be submitted by the Schools for the purpose of affiliation/recognition to the Authority concerned of Education Department, in the proforma prescribed at **Annexure-I** appended, duly marking a copy to the jurisdictional Divisional Fire Officer. The Officers of Telangana State Disaster Response & Fire Service will conduct surprise inspections randomly and if any deviations from Self Certification forms are noticed, the same will be intimated to the concerned authority of Education Department recommending for the cancellation of the affiliation/recognition.

7. Further, all Schools constructed after the Hon'ble Supreme Court Order dated:13.04.2009 shall follow the Safety norms of National Building Code of India. The Telangana State Disaster Response & Fire Services Department will issue Fire No Objection Certificate (NOC) for those schools which come within the purview of Section 13 (1) of Telangana Fire Service Act 1999, that is, Schools which more than 500 Sq.Mtrs in Plot area or 6 Mtrs and above in height duly following the norms of National Building Code of India.

8. All other schools constructed after the Hon'ble Supreme Court order dated:13.04.2009 and which do not come within the purview of the Telangana Fire Service Act, 1999 shall submit self certification forms in the proforma prescribed at **Annexure-II** appended to this order, to the concerned Authority of the Education Department for the purpose of affiliation/recognition by the Education Department duly marking a copy to the jurisdictional Divisional Fire Officer. The Officers of Telangana State Disaster Response & Fire Service will conduct surprise inspections

randomly and if any deviations from self certification forms are noticed, the same will be intimated to the concerned authority of Education Department recommending for the cancellation of the affiliation / recognition.

9. All the Departments concerned shall take necessary action accordingly in the matter.

**(BY ORDER AND IN THE NAME OF THE GOVERNOR OF TELANGANA)**

**RAJIV TRIVEDI  
PRINCIPAL SECRETARY TO GOVERNMENT**

To

The Secretary, School Education Department.

The Director General, Telangana State Disaster Response  
& Fire Service Department.

The Director, School Education Department, Telangana State, Hyderabad.

**Copy to:**

All the Regional Joint Directors of School Education through Director of School Education Department.

All the District Educational Officers in the State through the Director of School Education Department.

P.S. to Minister for Home.

P.S. to Minister for Education.


P.S. to Chief Secretary to Government.

P.S. to Principal Secretary to Govt., Home Department.

P.S. to Secretary to Govt., School Education Department.

Sf/Sc.

**// FORWARDED :: BY ORDER //**

  
**SECTION OFFICER**